




Type Examination Certificate **CML 18ATEX4314X Issue 1**

- 1 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 2 Equipment **Cable Gland Types SS2K****
- 3 Manufacturer **CMP Products Ltd**
- 4 Address **Unit 36 Nelson Way, Nelson Park
East, Cramlington, NE23 1WH,
United Kingdom**
- 5 The equipment is specified in the description of this certificate and the documents to which it refers.
- 6 CML B.V., Chamber of Commerce No 6738671, Hoogoorddreef 15, Amsterdam, 1101 BA, The Netherlands, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design of equipment intended for use in potentially explosive atmospheres given in Annex II of Directive 2014/34/EU.
The examination and test results are recorded in the confidential reports listed in Section 12.
- 7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to conditions of certification (affecting correct installation or safe use). These are specified in Section 14.
- 8 This Type Examination certificate relates only to the design and construction of the specified equipment or component. Further requirements of Directive 2014/34/EU Annex VIII apply to the manufacture of the equipment or component.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:
EN IEC 60079-0:2018 EN IEC 60079-15:2019
- 10 The equipment shall be marked with the following:



Ex nR IIC Gc

Ta= -60°C to +130°C (standard seal)
-20°C to +200°C (high temperature seal)

R C Marshall
Certification Officer



CML 18ATEX4314X
Issue 1

11 Description

The Cable Gland Types SS2K** are intended to terminate circular braided or unarmoured cables into enclosures without compromising the explosion protection provided by the enclosures in accordance with relevant codes of practice. They consist of a male-threaded front entry component, a main body component and an outer seal actuation nut. The front entry component, fitted with an elastomeric sealing ring and a Nylon 6 skid washer, is intended to screw into an entry point of its associated enclosure. The main body component, fitted with a locking ring, threads into the front entry component thereby effecting flameproof and environmental sealing onto the cable inner sheath. The outer seal actuation nut, fitted with an elastomeric sealing ring and a Nylon 6 skid washer, threads into the main body component thereby effecting environmental sealing onto the cable outer sheath. Two versions of the outer seal nut are available to allow alternative sizes of outer sheath to be gripped.

SS2K/PB Range

The SS2K/PB Range of Cable Glands are identical to the SS2K Range, except the front entry component is fitted with an electrical continuity device for use with lead sheathed cable.

SS2K/TA Range

The SS2K/TA Range of Cable Glands are identical to the SS2K/PB Range, except they are used to terminate circular cables with a tape armour sheath. They are for use in increased safety applications only.

SS2K-FF Range

The SS2K-FF range of cable glands are identical to the SS2K Range, except they are fitted with seals suited for use with flat form cables. They are for use in Group II applications only.

Design options

The front entry component may be manufactured with a profiled groove to captivate an O-ring seal which locates on the mating face with the associated enclosure. This option having the gland type designation prefixed with the letter R, e.g. 25RSS2K

Materials of manufacture:

SS2K/PB, SS2K/TA, and SS2K-FF Ranges of Cable Glands are manufactured in brass, stainless steel, mild steel & aluminium. All brass manufactured component parts can be optionally nickel plated. All mild steel manufactured components can be optionally zinc plated.



CML 18ATEX4314X
Issue 1

Examples of alternative entry component threadforms:

ET (Conduit)
PG
BSPP
BSPT
ISO
NPSM
NPT

Metric entry threads of all model ranges to be manufactured with a pitch between 0.7 mm and 2.0 mm, with 1.5 mm as standard.

The option to manufacture glands with entry threads that are one size up from the nominal quoted gland size.

Alternative material of manufacture of the skid washer to be the same as the gland material.

The front entry component may additionally be fitted with a metallic continuity diaphragm and skid washer for use with lead sheathed cable.

The main body component may additionally be fitted with an electrical continuity device for use with variable speed drive (VSD)/variable frequency drive (VFD) cables.

An optional outer seal nut with an anchor to which hose can be connected by a jubilee clip or similar

Type designation code:

SS2K	**	***	
			→VAR
			→PB
			TA
			FF
			HC

Fitted with an additional metallic continuity device for use with variable speed drive (VSD) / variable frequency drive (VFD) cables

Fitted with a metallic continuity diaphragm and skid washer for use with lead sheathed cable

Fitted with a metallic continuity diaphragm and skid washer for use with tape armoured cable

Fitted with seals suitable for use with flat form cables

Fitted with an outer seal nut with an anchor to which a hose can be connected by a jubilee clip or similar



**CML 18ATEX4314X
Issue 1**

The gland and seal sizes are determined by the entry thread and cable range take sizes:

Gland size	Entry thread	Entry thread 'B' version	Cable inner seal sheath range Ø (mm)		Cable outer seal sheath range Ø (mm)		Alternative outer seal sheath range Ø (mm)	
			Min.	Max.	Min.	Max.	Min.	Max.
16	M16 x 1.5	-	3.2	8.7	3.1	8.7	6.1	13.2
20s/16	M20 x 1.5	M25 x 1.5	3.2	8.7	3.1	8.7	6.1	13.2
20s/16/20s	M20 x 1.5	M25 x 1.5	3.2	8.7	6.1	11.7	9.5	15.9
20s	M20 x 1.5	M25 x 1.5	6.1	11.7	6.1	11.7	9.5	15.9
20s/20	M20 x 1.5	M25 x 1.5	6.1	11.7	6.5	14.0	12.5	20.9
20	M20 x 1.5	M25 x 1.5	6.5	14.0	6.5	14.0	12.5	20.9
20/25	M20 x 1.5	M25 x 1.5	6.5	14.0	11.1	20.0	18.2	26.2
25	M25 x 1.5	M32 x 1.5	11.1	20.0	11.1	20.0	18.2	26.2
25/32	M25 x 1.5	M32 x 1.5	11.1	20.0	17.0	26.3	23.7	33.9
32	M32 x 1.5	M40 x 1.5	17.0	26.3	17.0	26.3	23.7	33.9
32/40	M32 x 1.5	M40 x 1.5	17.0	26.3	22.0	32.2	27.9	40.4
40	M40 x 1.5	M50 x 1.5	23.5	32.2	22.0	32.2	27.9	40.4
40/50s	M40 x 1.5	M50 x 1.5	23.5	32.2	29.5	38.2	35.2	46.7
50s	M50 x 1.5	M63 x 1.5	31.0	38.2	29.5	38.2	35.2	46.7
50s/50	M50 x 1.5	M63 x 1.5	31.0	38.2	35.6	44.1	40.4	53.1
50	M50 x 1.5	M63 x 1.5	35.6	44.1	35.6	44.1	40.4	53.1
50/63s	M50 x 1.5	M63 x 1.5	35.6	44.1	40.1	50.1	45.6	59.4
63s	M63 x 1.5	M75 x 1.5	41.5	50.0	40.1	50.1	45.6	59.4
63s/63	M63 x 1.5	M75 x 1.5	41.5	50.0	47.2	56.0	54.6	65.9
63	M63 x 1.5	M75 x 1.5	47.2	56.0	47.2	56.0	54.6	65.9
63/75s	M63 x 1.5	M75 x 1.5	47.2	56.0	52.8	62.0	59.0	72.1
75s	M75 x 1.5	M90 x 2.0	54.0	62.0	52.8	62.0	59.0	72.1
75s/75	M75 x 1.5	M90 x 2.0	54.0	62.0	59.1	68.0	66.7	78.5
75	M75 x 1.5	M90 x 2.0	61.1	68.0	59.1	68.0	66.7	78.5
75/90	M75 x 1.5	M90 x 2.0	61.1	68.0	66.6	79.4	76.2	90.4
90	M90 x 2.0	M100 x 2.0	66.6	80.0	66.6	79.4	76.2	90.4
90/100	M90 x 2.0	M100 x 2.0	66.6	80.0	76.0	91.0	86.1	101.5
100	M100 x 2.0	M115 x 2.0	76.0	91.0	76.0	91.0	86.1	101.5
100/115	M100 x 2.0	M115 x 2.0	76.0	91.0	86.0	98.0	101.5	110.3
115	M115 x 2.0	M130 x 2.0	86.0	98.0	86.0	98.0	101.5	110.3
115/130	M115 x 2.0	M130 x 2.0	86.0	98.0	97.0	115.0	110.2	123.3
130	M130 x 2.0	Not available	97.0	115.0	97.0	115.0	110.2	123.3



CML 18ATEX4314X
Issue 1

Cable sizes for the SS2K-FF range only

Gland size	Entry thread	Entry thread 'B' version	Cable inner seal sheath range (mm)		Cable outer seal sheath range (mm)	
			Min.	Max.	Min.	Max.
20s	M20 x 1.5	M25 x 1.5	4.0 x 6.2	6.8 x 11.7	4.0 x 6.2	6.8 x 11.7
20	M20 x 1.5	M25 x 1.5	5.7 x 8.0	8.7 x 13.5	5.7 x 8.0	8.7 x 13.5

Notes:

- Sira 13ATEX4075X is superseded by this certificate.
- The product covered by Issue 0 of this certificate remains identical to that previously covered by Sira 13ATEX4075X.
- Where Sira 13ATEX4075X is specified in other product certification, or other technical specifications, this certificate reference for the product shall be used in its place; updating of the other product certificate or technical specification is not required.

12 Certificate history and evaluation Reports

Issue	Date	Associated report	Notes
0	12 Mar 2019	R12060G/00	Issue of Prime Certificate
1	20 Apr 2020	R12735D/00 R12922A	Introduction of Variation 1

Note: Drawings that describe the equipment or component are listed in the Annex.

13 Conditions of Manufacture

None.

14 Specific Conditions of Use (Special Conditions)

The following conditions relate to safe installation and/or use of the equipment.

- When the cable glands are supplied with an entry thread that is one size up from the nominal gland size, designated with the letter 'B' after the gland size, e.g. 32B****, they shall not be used with any adaptor device.

Certificate Annex



Certificate Number CML 18ATEX4314X
Equipment Cable Gland Types SS2K**
Manufacturer CMP Products Ltd

The following documents describe the equipment or component defined in this certificate:

Issue 0

Drawing No	Sheets	Rev	Approved date	Title
GA184	1 of 1	10	26 Mar 2019	SS2K General arrangement and marking
SCH0321	1 of 1	00	26 Mar 2019	Inner seal details
SCH0326	1 of 1	00	26 Mar 2019	SS2K outer seal details

Issue 1

Drawing No	Sheets	Rev	Approved date	Title
GA184	1 of 1	11	20 Apr 2019	SS2K General arrangement and marking