

CERTIFICATE OF COMPLIANCE

Certificate Number 20121005-E256367
Report Reference E256367-20060104
Issue Date 2012-OCTOBER-05

Issued to: **CMP PRODUCTS**
GLASSHOUSE ST
ST PETERS
NEWCASTLE-UPON-TYNE
NE6 1BS UNITED KINGDOM


This is to certify that representative samples of CABLE FITTINGS FOR USE IN ZONE CLASSIFIED HAZARDOUS LOCATIONS
See Addendum Page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 50, Enclosures for Electrical Equipment
UL 514B, Conduit, Tubing, and Cable Fittings
UL 2225, Cables and Cable Fittings for Use in Hazardous (Classified) Locations
EN 50014:1997
EN 50018:1984
EN 60529:1992

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20121005-E256367
Report Reference E256367-20060104
Issue Date 2012-OCTOBER-05

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Cat. No. C2KX provided with prefix numbers -16/20, -20S, -20, -25, -32, -40, -50S, -50, -63S, -63, -75S, -75 or -90. For use in Class I, Zone 1, AEx e II Hazardous Areas. For use only with marine shipboard cable employing copper, bronze, aluminum or stainless steel grounding braid. Thread sizes ½ to 3 in. NPT and M16 to M90 inclusive.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

