



EU Type Examination Certificate CML 18ATEX1334X Issue 0

- 1 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 2 Equipment **Type TC and TCCG Range of Cable Glands**
- 3 Manufacturer **CMP Products Ltd**
- 4 Address **Unit 36 Nelson Way,
Nelson Park East,
Cramlington, NE23 1WH,
United Kingdom**
- 5 The equipment is specified in the description of this certificate and the documents to which it refers.
- 6 CML B.V. , Chamber of Commerce No 6738671, Hoogoorddreef 15, Amsterdam, 1101 BA, The Netherlands, Notified Body Number 2776, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.
- 7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to conditions of safe use (affecting correct installation or safe use). These are specified in Section 14.
- 8 This EU Type Examination certificate relates only to the design and construction of the specified equipment or component. Further requirements of Directive 2014/34/EU Article 13 apply to the manufacture of the equipment or component and are separately certified.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:


EN 60079-0:2018

EN 60079-1:2014


EN 60079-7:2015+A1:2018

EN 60079-31:2014

- 10 The equipment shall be marked with the following:



Ex db IIC Gb
Ex eb IIC Gb



Ex ta IIIC Da



CML 18ATEX1334X
Issue 0

11 Description

The TC range of cable glands devices are designed to be threaded into suitably certified enclosures to permit the entry of un-armoured cables. Each gland comprises a threaded front item housing an elastomeric sealing ring assembly. The assembly is compressed by a threaded rear nut.

The TCCG type gland is a lighter weight version of the TC type gland and does not include an O-ring on the front entry item.

Materials of manufacture:

The standard material supplied is:

Brass	BS EN 12164:2011/ BS EN 12168:2011 Grade CuZn39Pb3 (CW614N) All brass manufactured component parts can be optionally nickel plated to a maximum of 0.008mm
-------	---

Alternate materials are:

Stainless steel	BS EN 10088-3:2014 Grades 316S11, 316S13, 316S31, 316S33, 316L
Mild steel	BS EN 10277-2:2008 Grades 220M07, 230M07 (EN1A) / 220M07Pb, 230M07Pb (EN1APb)
Aluminium	BS EN 573-3:2013 / BS EN 755-1-3:2008 Grade 6082 T6, 6262 T6 / BS EN 1676:2010 Grade LM25 TF

Alternative entry component thread forms:

Metric	ISO 965-1, ISO 965-3 medium fit (6g) for external threads
ET (Conduit)	BS31:1940 (1979), Table A
PG	DIN 40430:1971
BSPP	BS2779:1986 class A full form for external threads
BSPT	BS21:1985 standard threads only as clause 5.4, gauging to clause 5.2 system A
ISO	ISO 7/1:1994, gauging to ISO 7/2 clause 6.3 for external threads
NPT	ANSI/ASME B1.20.1-2013 gauging to clause 3.2 for external threads
NPSM	ANSI/ASME B1.20.1-2013 gauging to clause 6.4 for external threads



CML 18ATEX1334X
Issue 0

The gland seal sizes are proportional to the cable outer diameter as shown in the table below:

Size designation	Cable range (mm)	Comment
20s	3.2 -7.0	
20	6.5 - 14.0	removable insert
25	11.1 - 20.0	removable insert
32	17.0 - 26.3	removable insert
40	23.5 - 32.2	removable insert
50s	31.0- 38.2	removable insert
50	35.6 -44.1	
63s	41.5 - 50.1	
63	47.2 - 56.0	
75s	54.0 - 62.0	
75	61.1 - 68.0	
90	66.6 - 80.0	
100	76.0 - 90.0	

Notes:

- Sira 09ATEX1092X and IECEx SIR 09.0042X is superseded by this certificate.
- The product covered by Issue 0 of this certificate remains identical to that previously covered by Sira 09ATEX1092X and IECEx SIR 09.0042X.
- Where Sira 09ATEX1092X and/or IECEx SIR 09.0042X is specified in other product certification, or other technical specifications, this certificate reference for the product shall be used in its place; updating of the other product certificate or technical specification is not required.

12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	26 Mar 2019	R12060G/00	Issue of Prime Certificate

Note: Drawings that describe the equipment or component are listed in the Annex.

13 Conditions of Manufacture

None.

14 Specific Conditions of Use (Special Conditions)

The following conditions relate to safe installation and/or use of the equipment.

- The glands shall only be fitted to enclosures where the temperature, at the point of mounting, is below 110°C.
- The cable shall be effectively clamped as close as possible to the gland.
- When used for increased safety (Ex e) or dust protection by enclosure (Ex t) applications, the user shall provide a suitable interface seal between the gland and associated enclosure to maintain the appropriate level of ingress protection of IP54 for increased safety and IP6X for dust protection by enclosure.

Certificate Annex

Certificate Number CML 18ATEX1334X
Equipment Type TC and TCCG Range of Cable Glands
Manufacturer CMP Products Ltd



The following documents describe the equipment or component defined in this certificate:

Issue 0

Drawing No	Sheets	Rev	Approved date	Title
GA204	1 of 1	01	26 Mar 2019	TC General arrangement and marking
GA300	1 of 1	01	26 Mar 2019	TCCG General arrangement and marking
SCH0234	1 of 1	02	26 Mar 2019	Seal details
SCH0317	1 of 1	00	26 Mar 2019	TCCG item 1