



中国国家强制性产品认证证书



证书编号: 2020322313003284

认证委托人名称: CMP PRODUCTS LTD
 认证委托人地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
 生产者名称: CMP PRODUCTS LTD
 生产者地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
 生产企业名称: CMP PRODUCTS LTD
 生产企业地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

产品名称: 电缆引入装置
 系列、规格、型号: TMC2
 标准: GB 3836.1-2010、GB 3836.3-2010、GB 12476.1-2013、GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-G23-01:2019 的要求, 特发此证。

发证日期: 2020年11月20日 有效期至: 2025年11月19日

首次发证日期: 2020年11月20日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322313003284

APPLICANT: **CMP PRODUCTS LTD**
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

MANUFACTURER: **CMP PRODUCTS LTD**
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

FACTORY: **CMP PRODUCTS LTD**
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

PRODUCTNAME: CABLE GLANDS

SERIES,SPECIFICATION,MODEL: TMC2

STANDARDS: GB 3836.1-2010、GB 3836.3-2010、GB 12476.1-2013、GB 12476.5-2013

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:November 20, 2020

Valid until: November 19, 2025

Date of original certification:November 20, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0004047



中国国家强制性产品认证证书



证书编号：2020322313003284

附件

产品名称： 电缆引入装置

型号规格： TMC2

型号名称	电缆外护套直径范围 (mm)	标准 NPT 引入口螺 纹	可选 NPT 螺纹
TMC2050S	12.7-19.05	1/2"	3/4"
TMC2050	17.53-25.10	1/2"	3/4"
TMC2075	22.11-30.00	3/4"	1"
TMC2100	25.91-34.85	1"	1(1/4)"
TMC2125S	33.02-41.20	1(1/4)"	1(1/2)"
TMC2125	39.88-48.28	1(1/4)"	1(1/2)"
TMC2150S	41.91-50.82	1(1/2)"	2"
TMC2150	48.50-59.10	1(1/2)"	2"
TMC2200S	48.50-59.10	2"	2(1/2)"
TMC2200	57.70-69.00	2"	2(1/2)"
TMC2250	57.70-69.00	2(1/2)"	3"
TMC2300	66.50-82.70	3"	3(1/2)"
TMC2350	83.30-95.60	3(1/2)"	4"
TMC2400	94.00-108.00	4"	-

除以上所列螺纹规格以外，还可选用以下螺纹规格：

ISO 965-1, ISO965-3 中型 (6g) 外螺纹。

ANSI/ASME B1.20.1-1983 第 8.1 条外螺纹要求的 NPT 螺纹。

批准： 



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号：2020322313003284

附件

BS 31:1940(1979), 表 A。

DIN 40430:1971。

BS 2779: 1973 A 类所有外螺纹。

BS 21:1985 第 5.4 条, 第 5.2 条系统 A 要求的标准螺纹。

ISO 7/1:1982, 根据 ISO 7/2 6.3 条要求的外螺纹。

ANSI/ASME B1.20.1-1983 第 9 条外螺纹要求的螺纹。

防爆标志: Ex e IIC Gb; Ex tD A20 IP66。

电气参数: /

批 准:



上海仪器仪表自控系统检验测试所有限公司