



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx CML 18.0191X

Issue No: 0

Certificate history:

Issue No. 0 (2019-03-26)

Status: **Current**

Page 1 of 3

Date of Issue: **2019-03-26**

Applicant: **CMP Products Ltd**

Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH
United Kingdom

Equipment: **Type TC and TCCG Range of Cable Glands**

Optional accessory:

Type of Protection: **Flameproof "db", Increased Safety "eb", Dust Ignition "ta"**

Marking:

Ex db IIC Gb

Ex eb IIC Gb

Ex ta IIIC Da

*Approved for issue on behalf of the IECEx
Certification Body:*

R C Marshall

Position:

Certification Officer

*Signature:
(for printed version)*

Date:

2019-03-26

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

Certification Management Limited
Unit 1, Newport Business Park
New Port Road
Ellesmere Port, CH65 4LZ
United Kingdom





IECEX Certificate of Conformity

Certificate No: IECEx CML 18.0191X Issue No: 0
Date of Issue: **2019-03-26** Page 2 of 3
Manufacturer: **CMP Products Ltd**
Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH
United Kingdom

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2017 Edition:7.0	Explosive atmospheres - Part 0: Equipment - General requirements
IEC 60079-1 : 2014-06 Edition:7.0	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
IEC 60079-31 : 2013 Edition:2	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
IEC 60079-7 : 2015 Edition:5.0	Explosive atmospheres – Part 7: Equipment protection by increased safety "e"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

[GB/CML/ExTR19.0052/00](#)

Quality Assessment Report:

[GB/CML/QAR19.0001/00](#)



IECEX Certificate of Conformity

Certificate No: IECEx CML 18.0191X

Issue No: 0

Date of Issue: 2019-03-26

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The TC range of cable glands devices are designed to be threaded into suitably certified enclosures to permit the entry of un-armoured cables. Each gland comprises a threaded front item housing an elastomeric sealing ring assembly. The assembly is compressed by a threaded rear nut.

The TCCG type gland is a lighter weight version of the TC type gland and does not include an O-ring on the front entry item.

Refer to Annex for full description and conditions of manufacture.

SPECIFIC CONDITIONS OF USE: YES as shown below:

Refer to Annex for specific conditions of use.

Annex:

[IECEX CML 18.0191X Iss. 0 Certificate Annex.pdf](#)

Annexe to: IECEx CML 18.0191X Iss. 0
Applicant: CMP Products Ltd
Apparatus: Type TC and TCCG Range of Cable Glands



Description

The TC range of cable glands devices are designed to be threaded into suitably certified enclosures to permit the entry of un-armoured cables. Each gland comprises a threaded front item housing an elastomeric sealing ring assembly. The assembly is compressed by a threaded rear nut.

The TCCG type gland is a lighter weight version of the TC type gland and does not include an O-ring on the front entry item.

Materials of manufacture:

The standard material supplied is:

Brass	BS EN 12164:2011/ BS EN 12168:2011 Grade CuZn39Pb3 (CW614N) All brass manufactured component parts can be optionally nickel plated to a maximum of 0.008mm
-------	---

Alternate materials are:

Stainless steel	BS EN 10088-3:2014 Grades 316S11, 316S13, 316S31, 316S33, 316L
Mild steel	BS EN 10277-2:2008 Grades 220M07, 230M07 (EN1A) / 220M07Pb, 230M07Pb (EN1APb)
Aluminium	BS EN 573-3:2013 / BS EN 755-1-3:2008 Grade 6082 T6, 6262 T6 / BS EN 1676:2010 Grade LM25 TF

Alternative entry component thread forms:

Metric	ISO 965-1, ISO 965-3 medium fit (6g) for external threads
ET (Conduit)	BS31:1940 (1979), Table A
PG	DIN 40430:1971
BSPP	BS2779:1986 class A full form for external threads
BSPT	BS21:1985 standard threads only as clause 5.4, gauging to clause 5.2 system A
ISO	ISO 7/1:1994, gauging to ISO 7/2 clause 6.3 for external threads
NPT	ANSI/ASME B1.20.1-2013 gauging to clause 3.2 for external threads
NPSM	ANSI/ASME B1.20.1-2013 gauging to clause 6.4 for external threads

Unit 1, Newport Business Park
 New Port Road
 Ellesmere Port
 CH65 4LZ

T +44 (0) 151 559 1160
E info@cmllex.com

www.cmllex.com

Company Reg No. 8554022 VAT No. GB163023642



The gland seal sizes are proportional to the cable outer diameter as shown in the table below:

Size designation	Cable range (mm)	Comment
20s	3.2 -7.0	
20	6.5 - 14.0	removable insert
25	11.1 - 20.0	removable insert
32	17.0 - 26.3	removable insert
40	23.5 - 32.2	removable insert
50s	31.0- 38.2	removable insert
50	35.6 -44.1	
63s	41.5 - 50.1	
63	47.2 - 56.0	
75s	54.0 - 62.0	
75	61.1 - 68.0	
90	66.6 - 80.0	
100	76.0 - 90.0	

Notes:

- Sira 09ATEX1092X and IECEx SIR 09.0042X is superseded by this certificate.
- The product covered by Issue 0 of this certificate remains identical to that previously covered by Sira 09ATEX1092X and IECEx SIR 09.0042X.
- Where Sira 09ATEX1092X and/or IECEx SIR 09.0042X is specified in other product certification, or other technical specifications, this certificate reference for the product shall be used in its place; updating of the other product certificate or technical specification is not required.

Conditions of Manufacture

None.

Specific Conditions of Use (Special Conditions)

The following conditions relate to safe installation and/or use of the equipment.

- The glands shall only be fitted to enclosures where the temperature, at the point of mounting, is below 110°C.
- The cable shall be effectively clamped as close as possible to the gland.
- When used for increased safety (Ex e) or dust protection by enclosure (Ex t) applications, the user shall provide a suitable interface seal between the gland and associated enclosure to maintain the appropriate level of ingress protection of IP54 for increased safety and IP6X for dust protection by enclosure.