

CERTIFICATE OF COMPLIANCE

Certificate Number 20171006-E256367
Report Reference E256367-20060105
Issue Date 2017-OCTOBER-06

Issued to: CMP Products Ltd
Glasshouse St
St Peters, Newcastle-Upon-Tyne
NE6 1BS UNITED KINGDOM

**This is to certify that
representative samples of**

CABLE FITTINGS FOR USE IN ZONE CLASSIFIED
HAZARDOUS LOCATIONS

Cat. No. T3CDS provided with Prefix -16, -20S16, -20S, -
20, -25S, -25, -32, -40, -50S, -50, -63S, -63, -75S, -75 or -
90. For use in Class I, Zone 1, AEx e II Hazardous Areas.
For use with marine shipboard cable employing copper,
bronze, aluminum or stainless steel grounding braid.
Thread sizes ½ to 3 in. NPT and M20 to M90 inclusive.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 50, Enclosures for Electrical Equipment
UL 514B, Conduit, Tubing, and Cable Fittings
UL 2225, Cables and Cable Fittings for Use in Hazardous
(Classified) Locations
EN 50014:1997
EN 60529:1991
CSA C22.2 No. 174-M1984

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutUL/locations/>

